

REPORT NUMBER: SCALED FROM RAB00835
 ISSUE DATE: 05/21/15
 PREPARED FOR: RAB LIGHTING INC.
 CATALOG NUMBER: RAIL185YNW/347 RCL

PAGE: 1 OF 8
 DATE SAMPLE TESTED: 05/07/15

LUMINAIRE: EXTRUDED METAL HOUSING WITH HEAT SINK FINS, SIX WHITE CIRCUIT BOARD WITH NINETY SIX LEDS ON EACH BOARD, METAL REFLECTOR WITH SPECULAR FINISH, FLAT TRANSLUCENT LENS WITH FROSTED SIDE IN.

LAMPS: FIVE HUNDRED AND SEVENTY SIX LIGHT EMITTING DIODES (LEDs),
 NOTE: DATA SHOWN IS ABSOLUTE FOR THE SAMPLE PROVIDED.

TOTAL INPUT WATTS = 176.5 AT 480.0 VAC.

TEST PROCEDURE: IESNA LM-79-08



(SEE PAGE 2 FOR MORE INFORMATION)

CANDELA DISTRIBUTION

	0.0	45.0	90.0	135.0	180.0
0	8293	8293	8293	8293	8293
5	8208	8240	8279	8238	8203
15	7842	7819	7799	7810	7831
25	7118	7001	6876	6993	7103
35	6086	5885	5642	5873	6102
45	4885	4584	4310	4571	4871
55	3581	3276	3016	3265	3576
65	2317	2090	1898	2068	2315
75	1154	1035	914	1025	1154
85	222	250	265	247	218
90	12	68	96	66	6
95	5	4	10	2	2
105	5	3	2	3	3
115	5	4	3	3	3
125	5	3	3	3	3
135	4	4	3	4	4
145	4	4	4	5	5
155	5	5	5	5	6
165	5	5	6	6	6
175	5	6	7	7	7
180	7	7	7	7	7

FLUX

782
2202
3219
3671
3538
2944
2079
1105
300
16
3
3
3
3
3
2
2
1



LEGEND:
 0-deg: - - - - -
 90-deg: _____
 180-deg: — — — — —

ZONAL LUMEN SUMMARY

ZONE	LUMENS	%FIXT
0- 30	6203	31.2
0- 40	9874	49.7
0- 60	16355	82.3
0- 90	19839	99.8
90-120	23	0.1
90-130	26	0.1
90-150	31	0.2
90-180	36	0.2
0-180	19875	100.0

TOTAL INPUT WATTS = 176.5

EFFICACY = 112.6 Lm/W

CIE TYPE - DIRECT

PLANE : 0-DEG 90-DEG 180-DEG

SPACING CRITERIA : 1.2 1.1 1.2

Checked X.CAO
 Approved D.WANG-MUNSON

REPORT NUMBER: SCALED FROM RAB00835
ISSUE DATE: 05/21/15
PREPARED FOR: RAB LIGHTING INC.

PAGE: 2 OF 8
DATE SAMPLE TESTED: 05/07/15

ADDITIONAL INFORMATION

TEST DISTANCE: 28.25 FEET
DRIVER: 2 X RD-H100-A2000-480
LM-80 DATA AVAILABLE FROM MANUFACTURER FOR SOLID STATE SOURCE
ACCREDITED LABORATORY CODE 201058-0
LED
INDOOR, ARCHITECTURAL, COMMERCIAL DOCK, GYMNASIUM, INDUSTRIAL,
INSTITUTIONAL, MANUFACTURING, POOL, RECREATION, RETAIL, SPORTS,
DIRECT, HIGH BAY, LOW BAY, COLD STORAGE, DAMP LOCATION, WET
LOCATION
CEILING, SURFACE, SUSPENDED
3500
DLC

REPORT NUMBER: SCALED FROM RAB00835
ISSUE DATE: 05/21/15
PREPARED FOR: RAB LIGHTING INC.

PAGE: 3 OF 8
DATE SAMPLE TESTED: 05/07/15

PLANE : 0-DEG 90-DEG
BEAM ANGLE (50%) : 101.1 X 92.3 DEGREES
FIELD ANGLE (10%) : 156.1 X 152.1 DEGREES

REPORT NUMBER: SCALED FROM RAB00835
ISSUE DATE: 05/21/15
PREPARED FOR: RAB LIGHTING INC.

PAGE: 5 OF 8
DATE SAMPLE TESTED: 05/07/15

ZONAL LUMEN SUMMARY

0- 5	198.
5- 10	584.
10- 15	944.
15- 20	1259.
20- 25	1515.
25- 30	1704.
30- 35	1817.
35- 40	1854.
40- 45	1818.
45- 50	1719.
50- 55	1567.
55- 60	1376.
60- 65	1159.
65- 70	921.
70- 75	673.
75- 80	431.
80- 85	222.
85- 90	79.
90- 95	14.
95-100	2.
100-105	2.
105-110	2.
110-115	2.
115-120	2.
120-125	2.
125-130	1.
130-135	1.
135-140	1.
140-145	1.
145-150	1.
150-155	1.
155-160	1.
160-165	1.
165-170	1.
170-175	0.
175-180	0.

REPORT NUMBER: SCALED FROM RAB00835
ISSUE DATE: 05/21/15
PREPARED FOR: RAB LIGHTING INC.

PAGE: 6 OF 8
DATE SAMPLE TESTED: 05/07/15

5-DEGREE ZONAL LUMEN SUMMARY

0- 5	198
5- 10	584
10- 15	944
15- 20	1259
20- 25	1515
25- 30	1704
30- 35	1817
35- 40	1854
40- 45	1818
45- 50	1719
50- 55	1567
55- 60	1376
60- 65	1159
65- 70	921
70- 75	673
75- 80	431
80- 85	222
85- 90	79
90- 95	14
95-100	2
100-105	2
105-110	2
110-115	2
115-120	2
120-125	2
125-130	1
130-135	1
135-140	1
140-145	1
145-150	1
150-155	1
155-160	1
160-165	1
165-170	1
170-175	0
175-180	0

10-DEGREE ZONAL LUMEN SUMMARY

0- 10	782
0- 20	2984
0- 30	6203
0- 40	9874
0- 50	13411
0- 60	16355
0- 70	18434
0- 80	19539
0- 90	19839
0-100	19856
0-110	19859
0-120	19862
0-130	19865
0-140	19868
0-150	19871
0-160	19873
0-170	19875
0-180	19875

REPORT NUMBER: SCALED FROM RAB00835
 ISSUE DATE: 05/21/15

PAGE: 7 OF 8
 DATE SAMPLE TESTED: 05/07/15

PREPARED FOR: RAB LIGHTING INC.

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

EFFECTIVE FLOOR CAVITY REFLECTANCE 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	105	101	97	107	103	99	96	98	95	93	94	92	90	91	89	87	85
2	100	92	86	80	97	90	84	79	87	82	77	83	79	76	80	77	74	72
3	92	81	74	67	89	80	73	67	77	71	66	74	69	65	72	67	63	61
4	84	73	64	58	82	71	63	57	69	62	57	66	61	56	64	59	55	53
5	78	65	57	50	76	64	56	50	62	55	49	60	54	49	58	53	48	46
6	72	59	50	44	70	58	50	44	56	49	44	55	48	43	53	47	43	41
7	67	54	45	39	65	53	45	39	51	44	39	50	43	38	49	43	38	36
8	62	49	41	35	61	48	41	35	47	40	35	46	39	35	45	39	34	33
9	58	45	37	32	57	45	37	32	43	36	32	42	36	31	41	36	31	29
10	55	42	34	29	53	41	34	29	40	33	29	39	33	29	38	33	28	27


ALL CANDELA, LUMENS, LUMINANCE, AND VCP VALUES IN THIS REPORT ARE
 BASED ON ABSOLUTE PHOTOMETRY. THE COEFFICIENT OF UTILIZATION VALUES
 ARE BASED ON THE TOTAL ABSOLUTE LUMEN OUTPUT OF THIS LUMINAIRE SAMPLE.

REPORT NUMBER: SCALED FROM RAB00835
ISSUE DATE: 05/21/15
PREPARED FOR: RAB LIGHTING INC.

PAGE: 8 OF 8
DATE SAMPLE TESTED: 05/07/15

CONE OF LIGHT DIAGRAM

(diameter shown is where fc value is half the fc at nadir)



Note: The candela values used to generate this diagram were obtained by averaging the photometric data into a single plane.