

REPORT NUMBER: PRORATED FROM RAB02055

PAGE: 1 OF 8

ISSUE DATE: 06/15/16


PREPARED FOR: RAB LIGHTING INC.

CATALOG NUMBER: RDLED2AR8-20YN-TW

LUMINAIRE: FABRICATED METAL UPPER HOUSING AND BALLAST HOUSING, CAST BLACK PAINTED FINNED METAL HEAT SINK, CAST WHITE PAINTED METAL GIMBAL, 1 WHITE CIRCUIT BOARD WITH ONE LED, MOLDED PLASTIC REFLECTOR WITH SPECULAR FINISH, HOLOGRAPHIC FLAT PLASTIC LENS, CAST WHITE METAL LOWER HOUSING.

LAMP: ONE WHITE MULTI-CHIP LIGHT EMITTING DIODE (LED) WITH CLEAR HEMISPHERICAL INTEGRAL LENS, VERTICAL BASE-UP POSITION.

(SEE PAGE 2 FOR MORE INFORMATION)




DEG	CANDELA	LUMENS
0	3304	
5	2826	232
15	888	258
25	338	159
35	142	90
45	34	29
55	14	13
65	7	8
75	4	5
85	1	2
90	0	

ZONAL LUMEN SUMMARY		
ZONE	LUMENS	%FIXT
0- 30	649	81.6
0- 40	739	92.9
0- 60	781	98.2
0- 90	795	100.0
90-180	0	0.0
0-180	795	100.0

TOTAL INPUT WATTS = 8.1984
 EFFICACY = 97.0 Lm/W
 CIE TYPE - DIRECT
 LUMINAIRE SPACING CRITERION = 0.3
 LUMINOUS DIAMETER: 0.950

LUMINANCE DATA IN CANDELA/SQ METER
 ANGLE AVERAGE
 IN DEG

45	103574.
55	53203.
65	36103.
75	35371.
85	35013.



Checked X.CAO
 Approved D.WANG-MUNSON

REPORT NUMBER: PRORATED FROM RAB02055
ISSUE DATE: 06/15/16
PREPARED FOR: RAB LIGHTING INC.

PAGE: 2 OF 8

ADDITIONAL INFORMATION

NOTE: THIS REPORT WAS PRORATED FROM RAB02055 WHICH WAS
RDLED2AR8-20YYHC-TW. ACTUAL PERFORMANCE MAY VARY.

TOTAL INPUT WATTS: 8.1984 W AT 120.0 VOLTS

TEST PROCEDURE: IESNA LM-79-08

TEST DISTANCE: 28.25 FEET

PREPARED FOR: RAB LIGHTING INC.

LED DRIVER: RD-008-E1-A0200

NOTE: THIS REPORT WITH THE USE OF THE NVLAP LOGO SHALL NOT BE USED BY
THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR
ENDORSEMENT BY NVLAP, NIST, OR ANY AGENCY OF THE FEDERAL
GOVERNMENT.

REPORT NUMBER: PRORATED FROM RAB02055
ISSUE DATE: 06/15/16
PREPARED FOR: RAB LIGHTING INC.

PAGE: 3 OF 8

BEAM ANGLE (50%) : 20.4 DEGREES
FIELD ANGLE (10%): 50.7 DEGREES

REPORT NUMBER: PRORATED FROM RAB02055
ISSUE DATE: 06/15/16
PREPARED FOR: RAB LIGHTING INC.

PAGE: 4 OF 8

CANDELA DISTRIBUTION

	0.0
0.0	3304
2.5	3211
5.0	2826
7.5	2262
10.0	1692
12.5	1227
15.0	888
17.5	663
20.0	512
22.5	409
25.0	338
27.5	283
30.0	237
32.5	190
35.0	142
37.5	102
40.0	68
42.5	47
45.0	34
47.5	25
50.0	21
52.5	17
55.0	14
57.5	13
60.0	11
62.5	8
65.0	7
67.5	7
70.0	6
72.5	6
75.0	4
77.5	4
80.0	3
82.5	3
85.0	1
87.5	1
90.0	0

REPORT NUMBER: PRORATED FROM RAB02055
ISSUE DATE: 06/15/16
PREPARED FOR: RAB LIGHTING INC.

PAGE: 5 OF 8

ZONAL LUMEN SUMMARY

0- 5	74.
5- 10	158.
10- 15	147.
15- 20	111.
20- 25	87.
25- 30	72.
30- 35	56.
35- 40	34.
40- 45	18.
45- 50	11.
50- 55	7.
55- 60	6.
60- 65	4.
65- 70	3.
70- 75	3.
75- 80	2.
80- 85	1.
85- 90	1.

REPORT NUMBER: PRORATED FROM RAB02055
ISSUE DATE: 06/15/16
PREPARED FOR: RAB LIGHTING INC.

PAGE: 6 OF 8

5-DEGREE
ZONAL LUMEN SUMMARY

0- 5	74
5- 10	158
10- 15	147
15- 20	111
20- 25	87
25- 30	72
30- 35	56
35- 40	34
40- 45	18
45- 50	11
50- 55	7
55- 60	6
60- 65	4
65- 70	3
70- 75	3
75- 80	2
80- 85	1
85- 90	1
90- 95	0
95-100	0
100-105	0
105-110	0
110-115	0
115-120	0
120-125	0
125-130	0
130-135	0
135-140	0
140-145	0
145-150	0
150-155	0
155-160	0
160-165	0
165-170	0
170-175	0
175-180	0

10-DEGREE
ZONAL LUMEN SUMMARY

0- 10	232
0- 20	490
0- 30	649
0- 40	739
0- 50	768
0- 60	781
0- 70	789
0- 80	794
0- 90	795
0-100	795
0-110	795
0-120	795
0-130	795
0-140	795
0-150	795
0-160	795
0-170	795
0-180	795

REPORT NUMBER: PRORATED FROM RAB02055
ISSUE DATE: 06/15/16

PAGE: 7 OF 8

PREPARED FOR: RAB LIGHTING INC.

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

EFFECTIVE FLOOR CAVITY REFLECTANCE 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	112	109	107	112	109	107	106	105	104	102	102	101	99	98	97	97	95
2	109	105	102	99	107	103	100	97	100	98	95	97	95	93	95	93	91	90
3	105	99	95	92	103	98	94	91	95	92	89	93	90	88	91	89	87	85
4	101	94	90	86	99	93	89	86	91	87	85	89	86	84	87	85	83	81
5	97	90	85	81	95	89	84	81	87	83	80	86	82	80	84	81	79	78
6	93	86	81	77	92	85	80	77	84	80	77	82	79	76	81	78	76	74
7	90	82	77	74	89	82	77	74	80	76	73	79	76	73	78	75	73	71
8	87	79	74	71	86	79	74	71	78	73	70	77	73	70	76	72	70	69
9	84	76	71	68	83	76	71	68	75	71	68	74	70	67	73	70	67	66
10	81	73	69	65	80	73	68	65	72	68	65	72	68	65	71	67	65	64

ALL CANDELA, LUMENS, LUMINANCE, AND VCP VALUES IN THIS REPORT ARE BASED ON ABSOLUTE PHOTOMETRY. THE COEFFICIENT OF UTILIZATION VALUES ARE BASED ON THE TOTAL ABSOLUTE LUMEN OUTPUT OF THIS LUMINAIRE SAMPLE.

REPORT NUMBER: PRORATED FROM RAB02055
ISSUE DATE: 06/15/16
PREPARED FOR: RAB LIGHTING INC.

PAGE: 8 OF 8

CONE OF LIGHT DIAGRAM

(diameter shown is where fc value is half the fc at nadir)

