

Photometric Test Report

Relevant Standards

- ☒ IES LM-79-2008
- ☒ ANSI C82.77:2014

Prepared For

RAB Lighting Inc.

Room 6A33, No.1388, Wuzhong road, Shanghai, China

Xiao Xiang, 15921313292, gary.xiao@rabweb.com

Prepared By

Deliver Co., Ltd.

Block 11, 78 Keling Road, SSTP, Suzhou, China

0512-66801950, kevin.jia@szdeliver.com

Project Number

DLF1812112

Data Number

DLF1812112-5aMOD50

Test Date

2018/12/14

Issue Date


2018/12/15

Prepared By



Wangzun Zhu

Approved By



Kevin Jia

The results contained in this report pertain only to the tested sample.

This report shall not be reproduced, except in full, without written approval of Deliver Co., Ltd.

This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP.

1.0 Test Summary

DLC Technical Requirements v4.4

Outdoor - Mid Output Parking Garage Luminaire			
Requirement Category	Test Method	Requirements	Test value
Lamp Output (lm)	IES LM-79-2008	5000	5535
Minimum Luminaire Efficacy (lm/W)	IES LM-79-2008	90	117.8
Zonal Lumen Requirement (60°-80°)	IES LM-79-2008	≥30%	43.08%
Zonal Lumen Requirement (70°-80°)	IES LM-79-2008	≤25%	17.64%
Power (Input Wattage)	IES LM-79-2008	Worst Case	47.0
Input Voltage	IES LM-79-2008	Worst Case	480
Input Current	IES LM-79-2008	Worst Case	0.100
Allowable CCTs* (K)	IES LM-79-2008	≤5700	4781
Minimum CRI	IES LM-79-2008 CIE 13.3-1995	≥65	76
Power Factor	ANSI C82.77:2014	0.873	0.981
Total Harmonic Distortion (A%)	ANSI C82.77:2014	25.00%	19.02%

2.0 Test List

Test Item	Test	Test Date	Model Number	Sample No.
1	Integrating Sphere Test	2018/12/14	IVGT5-50L750Z4	E1
2	Goniophotometer Test	2018/12/14	IVGT5-50L750Z4	E1
3	THD and PF Test	2018/12/14	IVGT5-50L750Z4	E1

Remark(If any)


- 1、 This report shall not be used by the client to claim product endorsement by NVLAP, NIST or any agency of the US government.
- 2、 The results reported herein have been performed in accordance with the laboratory's terms of accreditation. This report shall not be reproduced except in full without the written approval of the Laboratory. The results in this report apply to the test sample(s) mentioned above at the time of the testing period only and are not to be used to indicate applicability to other similar products. This report does not imply that the product(s) has met the criteria for certification.

3.0 Production Description

Luminaire Description: IVGT5-50L750Z4

Electrical Specification: 480V,50/60HZ, 50W

Photos of Luminaire Characteristics



4.0 LM-79 Measurement and Test Results

4.1 Integrating Sphere Test

Model No.	IVGT5-50L750Z4	Sample ID.	E1
Operate time (Min.)	90	Stabilization time (Min.)	45

Test Method

The samples were tested according to the IES LM-79-2008.

Photometric parameters were measured using an integrating sphere, a spectroradiometer and software. The ambient temperature condition inside the sphere was maintained at $25^{\circ}\text{C} \pm 1^{\circ}\text{C}$.

The sample measurements were made using a spectroradiometer connected by a fiber optic cable and detector through the detector port of the integrating sphere.

The voltage of an AC power supply (RMS voltage) or DC power supply (instantaneous voltage) applied to the device under test shall be regulated to within ± 0.2 percent under load.

The sample was measured using 4π geometry and operated at rated voltage and was stabilized before measurement. Chromaticity coordinates, correlated color temperature and color rendering index were calculated from the spectral radiant flux measurements taken at 1 nm intervals over the range of 380 to 780 nm.

Test Conditions

Temperature ($^{\circ}\text{C}$)	Voltage (Vac)	Frequency (Hz)	Current (A)	Power (W)	Power Factor
25.3	479.93	60	0.100	47.0	0.981


Test Result

CCT (K)	CRI (Ra)	Duv
4781	76	6.0E-04

4.1 Integrating Sphere Test

Spectroradiometric Parameters

Results



Spectral values

DominantWavelength	582.79 nm
Purity	0.499
PeakWavelength	592.93 nm
Width50%:	102.21 nm


Color Coordinates

Correlated Color Temperatu 3060 K

x: 0.4319 u: 0.2487 u': 0.2487
y: 0.4008 v: 0.3462 v': 0.5193

CRI01	67.5	CRI09	-41.2
CRI02	84.4	CRI10	65.2
CRI03	93.3	CRI11	60.6
CRI04	65.2	CRI12	53.6
CRI05	67.4	CRI13	71.2
CRI06	78.9	CRI14	96.7
CRI07	74.8	CRI15	58.5
CRI08	38.9	CRI16	55.9

ResultsCRI 71.3



PlanckDistance 6.0E-004

4.0 LM-79 Measurement and Test Results

4.3 Goniophotometer Test

Model No.	IVGT5-50L750Z4	Sample ID.	E1
Operate time (Min.)	90	Stabilization time (Min.)	45

Test Method

The samples were tested according to the IES LM-79-2008.

Photometric parameters were measured using a type C goniophotometer and software.

The ambient temperature shall be maintained at $25^{\circ}\text{C} \pm 1^{\circ}\text{C}$, measured at a point not more than 1 m from the sample and at the same height as the sample.

The voltage of an AC power supply (RMS voltage) or DC power supply (instantaneous voltage) applied to the device under test shall be regulated to within ± 0.2 percent under load.

The samples were operated at rated voltage and was stabilized before measurement. Luminous flux, luminaire efficacy, zonal lumen were calculated from the software taken at 0.5° vertical intervals and 10° horizontal intervals.

Test Conditions


Temperature ($^{\circ}\text{C}$)	Voltage (Vac)	Frequency (Hz)	Current (A)	Power (W)	Power Factor	Orientation
25.1	480.00	60	0.100	47.0	0.980	Light Down

Test Result


Flux (lm)	Zonal Lumen Requirement (60° - 80°)	Zonal Lumen Requirement (70° - 80°)	Field Angle(10%)		Beam Angle(50%)		Luminous Efficacy (lm/W)
			Horizontal Spread	Vertical Spread	Horizontal Spread	Vertical Spread	
5535	43.08%	17.64%	177.3	176.2	170.2	169.3	117.8

4.3 Goniophotometer Test

Light Distrubtion Curve



Isolux Plot



4.3 Goniophotometer Test

Zonal Lumen Summary

DEG	LUMINOUS INTENSITY:cd									
γ	C0	C45	C90	C135	C180	C225	C270	C315		
10	419.8	425.5	427.1	424.2	423.4	416.1	411.9	415.2		
20	474.9	487.3	488.6	485.4	484.3	466.3	455.1	464.3		
30	561.2	581.8	585.0	579.4	570.9	550.0	525.7	547.7		
40	776.6	789.4	778.9	771.1	785.7	770.4	740.3	781.5		
50	1091	1110	1092	1088	1125	1079	1052	1099		
60	1387	1402	1393	1413	1453	1348	1357	1357		
70	1203	1222	1227	1276	1242	1095	1031	1053		
80	534.6	617.7	666.4	705.2	574.8	443.5	366.1	379.8		
90	4.380	22.54	42.75	54.77	11.85	0.3616	0.2790	0.3096		
100	0.6481	0.6001	0.5825	0.5946	0.5619	0.5949	0.5624	0.6022		
110	0.8385	0.8315	0.7608	0.7618	0.8902	0.9629	0.9383	0.8703		
120	0.8736	0.9074	0.8904	0.8695	1.016	1.213	1.089	1.110		
130	0.9359	1.005	1.054	0.9203	1.177	1.408	1.300	1.266		
140	0.9524	1.066	1.121	1.011	1.312	1.524	1.533	1.634		
150	0.9704	1.049	1.088	1.097	1.585	1.667	1.522	1.857		
160	2.080	1.007	1.056	1.050	2.182	1.383	1.543	1.662		
170	1.015	0.9550	0.9902	1.382	2.213	1.127	1.190	1.866		
180	0.9839	1.047	1.067	1.009	0.9879	0.9803	1.076	1.059		

4.3 Goniophotometer Test

ZONAL LUMEN SUMMARY

	Zonal (lm)		Total (lm)	Percent
0-10	42.19	0 - 10	42.19	0.76%
10-20	135.74	0 - 20	177.93	3.21%
20-30	256.92	0 - 30	434.85	7.86%
30-40	443.99	0 - 40	878.84	15.88%
40-50	773.00	0 - 50	1651.84	29.84%
50-60	1205.39	0 - 60	2857.23	51.62%
60-70	1407.84	0 - 70	4265.07	77.05%
70-80	976.61	0 - 80	5241.68	94.69%
80-90	282.10	0 - 90	5523.78	99.79%
90-100	5.73	0 - 100	5529.51	99.89%
100-110	0.83	0 - 110	5530.34	99.91%
110-120	0.98	0 - 120	5531.32	99.93%
120-130	1.05	0 - 130	5532.37	99.94%
130-140	1.00	0 - 140	5533.37	99.96%
140-150	0.89	0 - 150	5534.26	99.98%
150-160	0.68	0 - 160	5534.94	99.99%
160-170	0.40	0 - 170	5535.34	100.00%
170-180	0.13	0 - 180	5535.47	100.00%

3.2 Goniophotometer Test

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Coefficients Of Utilization - Zonal Cavity Method

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
Rw	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	104	97	91	85	101	94	89	84	90	85	81	86	82	78	82	79	76	73
2	90	79	70	62	87	77	68	61	73	66	59	70	63	58	66	61	56	54
3	80	66	55	46	77	64	54	46	61	52	45	57	50	44	55	48	43	40
4	71	56	44	35	68	54	43	35	51	42	35	49	40	34	46	39	33	31
5	64	48	36	28	61	46	36	28	44	35	27	42	34	27	40	32	27	24
6	58	42	31	23	56	41	30	23	39	29	22	37	28	22	35	27	22	19
7	53	37	26	19	51	36	26	19	34	25	19	33	24	18	31	24	18	16
8	49	33	23	16	47	32	23	16	31	22	16	29	21	15	28	21	15	13
9	45	30	20	14	44	29	20	14	28	19	13	27	19	13	25	18	13	11
10	42	27	18	12	41	26	18	12	25	17	12	24	17	12	23	16	11	9

5.0 THD and PF Test

Model No.	IVGT5-50L750Z4	Sample ID.	E1
-----------	----------------	------------	----

Test Method

The samples were tested according to the ANSI C82.77:2002.

The total harmonic distortion shall be measured to the 40th order.

The ambient temperature condition was maintained at $25^{\circ}\text{C} \pm 1^{\circ}\text{C}$. The sample measurements were made using a digital power meter and power supply. The sample was operated at rated voltage and was stabilized before measurement. The total harmonic distortion were calculated.

Test Results

Temperature (°C)	Voltage (Vac)	Frequency (Hz)	Current (A)	Power (W)	Power Factor	THD
25.1	479.93	60	0.100	47.0	0.981	19.02%

6.0 Equipment Information

Test Equipment			
Equipment ID	Equipment Name	Last Calibration	Calibration Due Date
DLF107	Integrating Sphere System	2017/12/28	2018/12/27
DLF108	Auxiliary Lamp	2017/12/28	2018/12/27
DLF122	Measurement Standard Lamp Standard Lamp Type: 220 V, 0.4720 A, Tungsten, Omni-directional	2017/12/28	2018/12/27
DLF116	AC Power Source	2017/12/28	2018/12/27
DLF113	Power Meter	2017/12/28	2018/12/27
DLF112	Temperature Recorder	2017/12/28	2018/12/27
DLF114	Temperature & Humidity Datalogger	2017/12/28	2018/12/27
DLF101	Goniophotometer	2017/12/28	2018/12/27
DLF125	Standard Lamp Standard Lamp Type: 76.58 V, 6.7875 A, Tungsten, Omni-directional	2017/12/28	2018/12/27
DLF104	AC Power Source	2017/12/28	2018/12/27
DLF507	DC Power Source	2017/12/28	2018/12/27
DLF102	Power Meter	2017/12/28	2018/12/27
DLF111	Temperature & Humidity Datalogger	2017/12/28	2018/12/27
DLF119	Power Meter	2017/12/28	2018/12/27
DLF031	Temperature data logger	2017/12/28	2018/12/27
DLF022	Digital power meter	2017/12/28	2018/12/27
DLF003	Temperature & Humidity Datalogger	2017/12/28	2018/12/27

***** End of Test Report*****