INSTRUCTIONS

PI S HYRRID



RAB Lighting is committed to creating high-quality, affordable, well-designed and energy-efficient LED lighting and controls that make it easy for electricians to install and end users to save energy. We'd love to hear your comments. Please call the Marketing Department at 888-RAB-1000 or email: marketing@rablighting.com

PLS-3.5-H-8XX-HYB



IMPORTANT

READ CAREFULLY BEFORE INSTALLING LAMPS. RETAIN THESE INSTRUCTIONS FOR FUTURE REFERENCE.

RAB lamps must be wired in accordance with the National Electrical Code and all applicable local codes. Proper grounding is required for safety. THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED.

WARNINGS:

- Risk of fire or electric shock. LED Retrofit Kit installation requires knowledge of luminaire electrical systems. If not qualified, do not attempt installation. Contact a qualified electrician. Installation should be performed only by a qualified electrician in accordance with the National Electrical Code and relevant local code.
- Risk of fire or electric shock. Install this kit only in the luminaires that have the construction features and dimensions shown in the photographs and/or drawings and where the input rating of the retrofit kit does not exceed the input rating of the luminaire.
- To prevent wiring damage or abrasion, do not expose wiring to edges of sheet metal or other sharp objects. Do not make or alter any open holes in an enclosure of wiring or electrical components during kit installation.
 Installers should not disconnect existing wires from lamp holder terminals to make new connections at lamp holder terminals.
 Instead installers should cut existing lamp holder leads away from the lamp holder and make new electrical connections to lamp holder lead wires by employing applicable connectors.

CAUTION

- RISK OF FIRE. IF THE LAMP OR LUMINAIRE EXHIBITS UNDESIRABLE OPERATION (BUZZING, FLICKERING, ETC.), IMMEDIATELY TURN OFF POWER, REMOVE LAMP FROM LUMINAIRE AND CONTACT MANUFACTURER.
- THIS LAMP ONLY OPERATES ON MAGNETIC BALLASTS. IF LAMP DOES NOT LIGHT WHEN THE LUMINAIRE IS ENERGIZED, REMOVE LAMP FROM LUMINAIRE AND CONTACT LAMP MANUFACTURER OR QUALIFIED ELECTRICIAN.
- Disconnect power at the source before installation, inspection or removal. Do not simply switch off fixture.
- This item is rated at 120-277V. Installer must determine whether line voltage 120-277V is available at the luminaire before installation.
- THIS DEVICE IS NOT INTENDED FOR USE WITH EMERGENCY EXITS
- · Not for use with luminaire ballast.
- · Do not use if product is damaged.
- This lamp is non-dimmable. Not for use with dimmers.
- "This luminaire has been modified to operate LED lamps" shall be marked on the retrofit lumin aire where readily visible by the user during normal maintenance including re-lamping.
- Risk of fire or electric shock. Do not open or modify. No user serviceable parts inside.
- Installers should not disconnect existing wires from lamp holder terminals to make new connections at lamp holder terminals.
 Instead installers should cut existing lamp holder leads away from the lamp holder and make new electrical connections to lamp holder lead wires by employing applicable connectors.
- SUITABLE FOR DAMP LOCATIONS. Suitable for use in wet locations when used in an outdoor-rated fixture. Not for use where directly exposed to the weather or water.
- Complies with Part 15 of FCC. Operation is subject to the following two conditions: (1) This device may not cause harmful
 interference, and (2) This device must accept any interference received including interference that may cause undesired
 operation.
- No external weight or mechanical force should be applied to lamp or components.
- THE RETROFIT ASSEMBLY IS ACCEPTED AS ACOMPONENT OF ALUMINAIRE WHERE THE SUITABILITY OF THE COMBINATION SHALL BE DETERMINED BY UL OR AUTHORITIES HAVING JURISDICTION.
- DO NOT INSTALL THIS LAMP IN A PRE-HEAT LUMINAIRE.
- WHEN DIRECT REPLACEMENT FOR SPECIFIC FLUORESCENT LAMPS, THIS LAMP ONLY OPERATES ON MAGNETIC BALLASTS.
 IF LAMP DOES NOT LIGHT WHEN THE LUMINAIRE IS ENERGIZED, REMOVE LAMP FROM LUMINAIRE AND CONTACT LAMP MANUFACTURER OR QUALIFIED ELECTRICIAN.

INSTRUCTIONS

PI S HYRRID



RAB Lighting is committed to creating high-quality, affordable, well-designed and energy-efficient LED lighting and controls that make it easy for electricians to install

NOTE:

- This retrofit kit is for a 2 PIN MOUNT and can replace 5W.7W and 9W CFL lamps with G23 bases.
- This lamp is non-dimmable. Not for use with dimmers.
- · Operates on magnetic ballasts only.
- This lamp is not compatible with luminaires that use a remote starter.
- · Suitable to replace compact fluorescent lamps as specified on the product label.

WIRING DIAGRAM

- Read all WARNINGS before continuing this section.
- 2) Ensure fixture is 120-277V
- 3) Make sure POWER IS TURNED OFF AT THE SOURCE
- 4) Remove lens if applicable, remove cover and fluorescent lamp
- 5) Before rewiring, check the ballast type and refer to the relevant diagram
- 6) Before rewiring, please check the number of lamps per fixture and refer to the relevant diagram.
- If fixture is new without ballast, please refer to Cf. Diagram 1.
- If fixture ballast type is magnetic please refer to Cf. Diagram 2. 8)
- If fixture ballast type is magnetic please refer to Cf. Diagram 3, installation without wiring modification.
- This device is powered by two pins: Install lamp into the wired lampholder end. 10)
- Visibly affix "Modification Sticker" and reinstall housing cover and lens if applicable
- Return power back to source and installation is now complete.


Diagram 1 - New fixture without ballast wiring



Diagram 3 - Magnetic ballast fixture without wiring modification



Diagram 2 - Magnetic ballast fixture wiring modification





Easy Answers