LM-79-08 Test Report

For

RAB LIGHTING INC

(Brand Name: N/A)

170 Ludlow Ave, PO BOX 970, Northvale, NJ 07647-2305 USA

Model name(s): DLC0046(C8R82840UNVW)

Report Type: Testing and Report According to IES LM-79-2008

Type of

Downlights

Luminaire:

Report Date:

2020-09-07

Prepared By:

Test & Report By:

Review By:

0-11-10

Engineer: Sun Fangfang Manager: Huang Qichong

1.1 Rated Values:						
Rated Voltage / Frequency	120V-277Vac, 50/60 Hz					
Nominal Power	82.0W					
Rated Initial Lamp Lumen	8000 lm					
Declared CCT	4000K					

1.2 Test Specifications:

1.2 Test Specifications.	
	1. Total Luminous Flux
	2. Luminous Distribution Intensity
	3. Luminous Efficacy
Test item	4. Correlated Color Temperature
	5. Color Rendering Index
	6. Chromaticity Coordinate
	7. Electrical Parameters
	1. IES LM-79-2008 Electrical and Photometric Measurements of
	Solid-State Lighting Products
	2. ANSI C78.377-2015 Specifications for the Chromaticity of Solid
	State Lighting Products
	3. CIE 13.3-1995 Method of Measuring and Specifying Colour
Reference Standard	Rendering Properties of Light Sources
	4. CIE 15-2004 Technical Report Colorimetry
	5. IESNA LM-16-93 Practical Guide to Colorimetry of Light Source
	6. IESNA TM-16-05 Technical Memorandum on Light Emitting
	Diode (LED) Sources and Systems
Reference Work Instruction	QD25

1.3 Test Methods

1) Photometric and Light Distribution Measurement – Goniophotometer Method:

Photometric parameters were measured using the goniophotometer and software. The ambient temperature shall be maintained at 25°C $\pm 1^{\circ}\text{C}$, measured at a point not more than 1 m from the sample and at the same height as the sample. The sample was operated at 120 or rated Volts AC, 60Hz. It was stabilized before measurement was made. Luminous flux, luminaire efficacy, zonal lumen were calculated from the software taken at 1°vertical intervals and 22.5°horizontal intervals.

2) Chromaticity Measurement – Sphere-Spectroradiometer Method:

Chromaticity parameters were measured using an integrating sphere, a spectroradiometer and software. The ambient temperature condition inside the sphere was maintained at $25^{\circ}\text{C} \pm 1^{\circ}\text{C}$. The sample measurements were made using a spectroradiometer connected by a fiber optic cable and detector through the detector port of the integrating sphere. The sample was operated at 120 or rated Volts AC, 60Hz. It was stabilized before measurement was made. Chromaticity coordinates, correlated color temperature and color rendering index were calculated from the spectral power distribution taken at 5 nm intervals over the range of 380 to 780 nm.

3) Electrical Measurements:

Electrical parameters were measured using power meters incorporated in goniophotometer or sphere-spectroradiometer system. The ambient temperature surrounding the sample was maintained at 25° C $\pm 1^{\circ}$ C. The sample was operated at 120 or rated Volts AC, 60Hz. It was stabilized before measurement was made. Voltage, frequency, current, power, power factor and total harmonic distortion were measured by and read from the power meter.

2.1.1 Electrical, Photometric and Chromaticity Measurements

Test date	2020-09-07	Test Ambient:	25.3 ℃
Test Orientation	As intended	Stabilization Time (min)	90
Model Number	DLC0046(C8R82840UNVW)	4000K	

Electrical Measurement:

Sample No.	Voltage (Vac)	Frequency (Hz)	Current (A)	Power (W)	Power Factor
202008280031	120.0	60	0.633	75.60	0.995

Chromaticity Measurement - Sphere-Spectroradiometer Method:

Parameter	Result
Test Voltage (V)	120
Frequency (Hz)	60
CCT (K)	3909
Duv	0.0016
Chromaticity (x, y)	x=0.3858 y=0.3835
Chromaticity (u', v')	u'=0.2259 v'=0.5053
Color Rendering Index (CRI)	81.9
R9	6


Special Color Rendering Indices										
R1	80	R9	6							
R2	88	R10	71							
R3	94	R11	78							
R4	80	R12	59							
R5	80	R13	82							
R6	83	R14	97							
R7	86	R15	74							
R8	64									


Photometric Measurement – Goniophotometer Method:

Parameter	Result
Test Voltage (V)	120.0
Frequency (Hz)	60
Total Luminous (lm)	8966.8
Luminous Efficacy (lm/W)	118.61
Beam Angle (°)	82.7
Center Beam Candle Power (cd)	4782

Parameter	Result
Test Voltage (V)	277.0
Frequency (Hz)	60
Total Luminous (lm)	9026.0
Luminous Efficacy (lm/W)	119.98

Spectral Power Distribution & Chromaticity Diagram





Zonal Lumen Tabulation

Zonal Lumen Summary										
Zone	Lumens	% Luminaire								
0-30	3517.0	39.2%								
0-40	5443.1	60.7%								
0-60	7909.5	88.2%								
60-90	1057.3	11.8%								
70-100	479.6	5.3%								
90-120	0.0	0.0%								
0-90	8966.8	100.0%								
90-180	0.0	0.0%								
0-180	8966.8	100.0%								

Lumens Per Zone													
Zone	Lumens	% Total	Zone	Lumens	% Total								
0-10	448.3	5.0%	90-100	0.0	0.0%								
10-20	1251.7	14.0%	100-110	0.0	0.0%								
20-30	1817.0	20.3%	110-120	0.0	0.0%								
30-40	1926.1	21.5%	120-130	0.0	0.0%								
40-50	1523.3	17.0%	130-140	0.0	0.0%								
50-60	943.1	10.5%	140-150	0.0	0.0%								
60-70	577.7	6.4%	150-160	0.0	0.0%								
70-80	70-80 348.0 3.9		160-170	0.0	0.0%								
80-90	131.6	1.5%	170-180	0.0	0.0%								


Photometric Data

Height

Eavg, Enax

Angle: 82.72deg

Diameter




Report No: 20200907003

MOUNTING HEIGHT: 33'(10.0m)

Table1																UNI	T: cd	
C(DEG)																		
7 (DEG)	0	22.5	45	67.5	90	112.5	135	157.5	180	202.5	225	247.5	270	292.5	315	337.5		
0	4780	4780	4780	4780	4780	4780	4780	4780	4780	4780	4780	4780	4780	4780	4780	4780		
5	4743	4740	4739	4740	4731	4734	4734	4737	4735	4731	4737	4738	4740	4735	4745	4740		
10	4627	4627	4620	4622	4609	4611	4608	4615	4610	4607	4616	4613	4621	4615	4628	4624		
15	4454	4455	4447	4449	4431	4437	4431	4439	4435	4428	4437	4436	4445	4445	4455	4448		
20	4247	4249	4240	4238	4227	4224	4218	4224	4218	4212	4224	4222	4238	4235	4244	4239		
25	3992	3995	3979	3982	3959	3965	3951	3963	3957	3948	3963	3960	3978	3976	3988	3979		
30	3592	3612	3586	3608	3557	3586	3554	3588	3582	3549	3589	3563	3604	3578	3612	3583		
35	3104	3135	3098	3121	3074	3102	3068	3102	3093	3063	3101	3079	3117	3089	3128	3097		
40	2553	2584	2548	2574	2529	2555	2524	2558	2546	2516	2552	2529	2565	2540	2574	2546		
45	1978	2003	1975	1995	1958	1980	1956	1986	1974	1948	1978	1957	1988	1966	1993	1968		
50	1453	1466	1450	1458	1439	1448	1438	1454	1444	1432	1446	1435	1451	1441	1457	1444		
55	1040	1049	1037	1042	1028	1036	1027	1039	1030	1021	1031	1023	1034	1028	1038	1030		
60	765	771	764	768	758	763	758	765	757	751	758	754	760	756	763	757		
65	575	579	575	578	571	574	571	576	571	566	572	568	573	569	574	570		
70	454	456	454	456	451	454	452	455	452	450	453	450	453	451	453	451		
75	328	330	328	329	326	327	325	327	328	326	328	327	329	329	330	329		
80	213	212	213	211	210	209	210	209	212	213	213	214	214	216	215	216		
85	115	117	114	116	112	114	112	114	119	117	119	118	121	119	122	120		
90	49.1	49.1	49.1	49.1	49.1	49.0	49.1	49.1	55.2	55.1	55.1	55.2	55.2	55.2	55.3	55.3		

3. Product Photo





***** END OF REPORT *****